



क.रा.बी.नि.अस्पताल / ESIC Hospital समीप पुलिस लाइन, रुद्रपुर,उत्तराखंड Near Police Line, Rudrapur,Uttarakhand Email :<u>ms-rudrapur.uchal@esic.nic.in</u> Website :<u>www.esic.nic.in/www.esic.in</u> Phone: 05944-297829

File No: 611/ESICH/RDR/Firefighting/PMD-2024

Date: 01.03.2025

## Corrigendum

Subject: Procurement of Fixed Clean Agent Gas based Fire Suppression System through GeM.

*Ref: GEM/2025/B/5846942.* 

Query (ies) has (have) been received from agency (ies) regarding the drawing of the area/ panels intended to be covered under the said tender.

In this regard, this is to inform the interested bidder (s) that this tender is intended to cover the substation panel in service block, Data server rack (42 U) in 2nd floor and CCTV rack (42 U) in Ground Floor.

Moreover, as far as drawing of the panels are concerned, all the interested bidder (s) advised to visit the hospital for a physical inspection of the panel (s)/ rack (s) to obtain necessary information required for bid submission as no 'As Built' or 'General Drawing' available with the hospital.

This is for kind information and necessary action.

This issue with approval of Competent Authority.

**Branch Officer** 

PMD